



THE LOCAL GUYS TEST & TAG CERTIFICATE OF COMPLIANCE

This certificate acknowledges that

BUSINESS NAME

Is compliant with their obligations and duty of care for staff, visitors and contractors under the relevant New Zealand standards for the services listed.

Services Completed:

Electrical Appliance Test & Tag

Residual Current Device (RCD) Testing

Fire Equipment Maintenance

Microwave Radiation Leakage Testing

Date of Certification:

24 February 2022

Electrical Appliance Testing Valid Until:

24 February 2023

Residual Current Device Testing Valid Until:

24 August 2022

Fire Equipment Maintenance Valid Until:

24 August 2022

Your Name
(Licence Number)

This certificate is property of The Local Guys Test & Tag (Territory)

Tel: 0800 733 858 | Email: admin@thelocalguys.co.nz

www.thelocalguystestandtag.co.nz



Prepared For:
 BUSINESS NAME
 STREET, SUBURB
 CITY POSTCODE, New Zealand

Created By:
 Franchise Partner Name
 The Local Guys Test & Tag (Territory)

Summary:
 Date of Inspection: 10/01/22
 Test Count: 37 Items Passed: 35 Items Failed: 2

Summary of Failed Items:

Identifier	Item	Location	Reason	Action Taken
12	Lead	Reception	Exposed wires	Removed from site
31	Sander	Workshop	Damaged plug	Notified John - Removed

Electrical Appliance Testing Report

Test Date	Identifier	Description	Class	Test Interval (mnts)	Vis Test	Elec Test	Status	Next Test Due Date
Reception								
10/01/21	1	Fan	I	12	✓	✓	Passed	10/01/22
10/01/21	2	Laminator	I	12	✓	✓	Passed	10/01/22
10/01/21	3	Monitor	I	12	✓	✓	Passed	10/01/22
10/01/21	4	Phone	II	12	✓	✓	Passed	10/01/22
10/01/21	5	Radio	II	12	✓	✓	Passed	10/01/22
10/01/21	6	Extension Cord	Lead	12	✓	✓	Passed	10/01/22
10/01/21	7	Extension Cord	Lead	12	✓	✓	Passed	10/01/22
10/01/21	8	Extension Cord	Lead	12	✓	✓	Passed	10/01/22
10/01/21	9	Extension Cord	Lead	12	✓	✓	Passed	10/01/22
10/01/21	10	Lead	II	12	✓	✓	Passed	10/01/22
10/01/21	11	Lead	II	12	✓	✓	Passed	10/01/22
10/01/21	12	Lead	II	12	✗	✗	Failed	10/01/21
10/01/21	13	Power Board	EPOD	12	✓	✓	Passed	10/01/22
10/01/21	14	Power Board	EPOD	12	✓	✓	Passed	10/01/22
10/01/21	5001	Monitor	I	60	✓	✓	Passed	10/01/22
10/01/21	5002	Monitor	I	60	✓	✓	Passed	10/01/22
10/01/21	5003	Computer	I	60	✓	✓	Passed	10/01/22
Kitchen								
10/01/21	15	Coffee Machine	II	12	✓	✓	Passed	10/02/22
10/01/21	16	Kettle	II	12	✓	✓	Passed	10/02/22
10/01/21	17	Coffee Machine	II	12	✓	✓	Passed	10/02/22
10/01/21	18	Power Board	EPOD	12	✓	✓	Passed	10/02/22
10/01/21	19	Extension Cord	Lead	12	✓	✓	Passed	10/02/22
10/01/21	20	Double Adaptor	I	12	✓	✓	Passed	10/02/22
10/01/21	21	Microwave	I	12	✓	✓	Passed	10/02/22
10/01/21	22	Fridge	I	12	✓	✓	Passed	10/02/22
Workshop								
10/01/21	23	Circular Saw	II	6	✓	✓	Passed	10/07/21
10/01/21	24	Carpet Cleaner	I	6	✓	✓	Passed	10/07/21

10/01/21	26	Light	II	6	✓	✓	Passed	10/07/21
10/01/21	27	Polivac	I	6	✓	✓	Passed	10/07/21
10/01/21	28	Charger	II	6	✓	✓	Passed	10/07/21
10/01/21	29	Battery Charger	II	6	✓	✓	Passed	10/07/21
10/01/21	30	Heat Gun	II	6	✓	✓	Passed	10/07/21
10/01/21	31	Sander	I	6	×	×	Failed	10/01/21
10/01/21	32	Charger	II	6	✓	✓	Passed	10/07/21
10/01/21	33	Charger	II	6	✓	✓	Passed	10/07/21
10/01/21	34	Angle grinder	II	6	✓	✓	Passed	10/07/21

Inspection Completion & Compliance

All testing has been completed inline with the AS/NZS3760 standard.

The regular testing and tagging of appliances is a necessary part of an electrical safety management plan to reduce the risk of hazards and ensure the safety of those using electrical equipment within a workplace.